

Air Conditioning

Contractor must verify the following items and provide pictures detailing each item once A/C has been changed (Note: The following items must be submitted by the contractor in order to receive your deposit refund):

- Identify each unit with large spray-painted numbers
- Armor flex on suction line is good
- Secure the unit to the stand (Tie Downs)
- Hurricane strapping of air condensing unit
- Electrical box cover is good and watertight
- Electrical box is good and watertight
- Electrical disconnect switch is operational
- If new fusible link disconnects, verify fuses match A/C specs
- Electrical whip must be secured above the ground (8")
- Safe-T-Switch must be installed on the interior condensation A/C unit.



Note: Please submit pictures detailing each item to Kingscreeksouth3@gmail.com.
Include owner's name and unit number in subject line.